



OPTIONAL ANNUAL REPORT TEMPLATE

Drinking-Water System Number:	260005463
Drinking-Water System Name:	Newbury Distribution System
Drinking-Water System Owner:	Corporation of the Village of Newbury
Drinking-Water System Category:	Large Municipal Residential
Period being reported:	January 1 – December 31, 2016

Complete if your Category is Large Municipal Residential or Small Municipal Residential

Complete for all other Categories.

<p>Does your Drinking-Water System serve more than 10,000 people? Yes [] No [X]</p> <p>Is your annual report available to the public at no charge on a web site on the Internet? Yes [X] No []</p> <p>Location where Summary Report required under O. Reg. 170/03 Schedule 22 will be available for inspection.</p> <div style="border: 1px solid black; padding: 5px; margin-top: 10px;"> <p>Village of Newbury 22910 Hagerty Road P.O. Box 130 Newbury, ON N0L 1Z0</p> </div>	<p>Number of Designated Facilities served:</p> <div style="border: 1px solid black; padding: 2px; margin: 5px 0;">N/A</div> <p>Did you provide a copy of your annual report to all Designated Facilities you serve? Yes [] No []</p> <p>Number of Interested Authorities you report to: <div style="border: 1px solid black; padding: 2px; margin: 5px 0;">N/A</div></p> <p>Did you provide a copy of your annual report to all Interested Authorities you report to for each Designated Facility? Yes [] No []</p>
--	---

Note: For the following tables below, additional rows or columns may be added or an appendix may be attached to the report

List all Drinking-Water Systems (if any), which receive all of their drinking water from your system:

Drinking Water System Name	Drinking Water System Number
None	

Did you provide a copy of your annual report to all Drinking-Water System owners that are connected to you and to whom you provide all of its drinking water? Yes [] No []



Indicate how you notified system users that your annual report is available, and is free of charge.

- Public access/notice via the web
- Public access/notice via Government Office
- Public access/notice via a newspaper
- Public access/notice via Public Request
- Public access/notice via a Public Library
- Public access/notice via other method (Newsletter)

Describe your Drinking-Water System

The Newbury Distribution System receives water from the Southwest Middlesex Distribution System to supply water to the Village of Newbury and the Four Counties Hospital.

List all water treatment chemicals used over this reporting period

There are no chemicals used in the Newbury Distribution System. The Southwest Middlesex Distribution System provides the Newbury Distribution System with secondary disinfection using sodium hypochlorite.

Were any significant expenses incurred to?

- Install required equipment
- Repair required equipment
- Replace required equipment

Please provide a brief description and a breakdown of monetary expenses incurred

Maintenance was done on each hydrant as well as painting and colour coding according to flow testing performed in 2016. The Village initiated a program for replacement of service rods and boxes with stainless steel parts. Approximate cost was \$20,000.

Provide details on the notices submitted in accordance with subsection 18(1) of the Safe Drinking-Water Act or section 16-4 of Schedule 16 of O.Reg.170/03 and reported to Spills Action Centre

Incident Date	Parameter	Result	Unit of Measure	Corrective Action	Corrective Action Date
None					



Microbiological testing done under the Schedule 10, 11 or 12 of Regulation 170/03, during this reporting period.

	Number of Samples	Range of E.Coli Or Fecal Results (min #)-(max #)	Range of Total Coliform Results (min #)-(max #)	Number of HPC Samples	Range of HPC Results (min #)-(max #)
Raw	N/A				
Treated	N/A				
Distribution	104	0 – 0	0 – 0	52	<10 – 30

Operational testing done under Schedule 7, 8 or 9 of Regulation 170/03 during the period covered by this Annual Report.

	Number of Grab Samples	Range of Results (min #)-(max #)
Turbidity	N/A	
Chlorine	469	0.47 -1.65 mg/L
Fluoride (If the DWS provides fluoridation)	1	0.11 mg/L

NOTE: For continuous monitors use 8760 as the number of samples.

*NOTE: Record the unit of measure if it is **not** milligrams per litre.*

Summary of additional testing and sampling carried out in accordance with the requirement of an approval, order or other legal instrument.

Date of legal instrument issued	Parameter	Date Sampled	Result	Unit of Measure
None				

Summary of Inorganic parameters tested during this reporting period or the most recent sample results

Parameter	Sample Date Jan 19/2016	Sample Date Apr 19/2016	Sample Date Jul 18/2016	Sample Date Oct 24/2016
Antimony	N/A	N/A	N/A	N/A
Arsenic	N/A	N/A	N/A	N/A
Barium	N/A	N/A	N/A	N/A
Boron	N/A	N/A	N/A	N/A
Cadmium	N/A	N/A	N/A	N/A
Chromium	N/A	N/A	N/A	N/A
*Lead	N/A	N/A	N/A	N/A
Mercury	N/A	N/A	N/A	N/A
Selenium	N/A	N/A	N/A	N/A
Sodium - ug/L	11,000	N/A	N/A	N/A
Uranium	N/A	N/A	N/A	N/A
Fluoride - mg/L	0.11	N/A	N/A	N/A

Nitrite	N/A	N/A	N/A	N/A
Nitrate	N/A	N/A	N/A	N/A

*only for drinking water systems testing under Schedule 15.2; this includes large municipal non-residential systems, small municipal non-residential systems, non-municipal seasonal residential systems, large non-municipal non-residential systems, and small non-municipal non-residential systems

Summary of lead testing under Schedule 15.1 during this reporting period

(applicable to the following drinking water systems; large municipal residential systems, small municipal residential systems, and non-municipal year-round residential systems)

Location Type	Number of Samples	Range of Lead Results ug/L (min#) – (max #)	Number of Exceedances / Adverses
Residential	N/A		
Non-Residential	N/A		
Distribution	N/A		

Summary of Organic parameters sampled during this reporting period or the most recent sample results

Parameter	Sample Date Jan 19/2016	Sample Date Apr 19/2016	Sample Date Jul 18/2016	Sample Date Oct 24/2016
Alachlor	N/A	N/A	N/A	N/A
Aldicarb	N/A	N/A	N/A	N/A
Aldrin + Dieldrin	N/A	N/A	N/A	N/A
Atrazine + N-dealkylated metabolites	N/A	N/A	N/A	N/A
Azinphos-methyl	N/A	N/A	N/A	N/A
Bendiocarb	N/A	N/A	N/A	N/A
Benzene	N/A	N/A	N/A	N/A
Benzo(a)pyrene	N/A	N/A	N/A	N/A
Bromoxynil	N/A	N/A	N/A	N/A
Carbaryl	N/A	N/A	N/A	N/A
Carbofuran	N/A	N/A	N/A	N/A
Carbon Tetrachloride	N/A	N/A	N/A	N/A
Chlordane (Total)	N/A	N/A	N/A	N/A
Chlorpyrifos	N/A	N/A	N/A	N/A
Cyanazine	N/A	N/A	N/A	N/A
Diazinon	N/A	N/A	N/A	N/A
Dicamba	N/A	N/A	N/A	N/A
1,2-Dichlorobenzene	N/A	N/A	N/A	N/A
1,4-Dichlorobenzene	N/A	N/A	N/A	N/A
Dichlorodiphenyltrichloroethane (DDT) + metabolites	N/A	N/A	N/A	N/A
1,2-Dichloroethane	N/A	N/A	N/A	N/A
1,1-Dichloroethylene (vinylidene chloride)	N/A	N/A	N/A	N/A

Dichloromethane	N/A	N/A	N/A	N/A
2-4 Dichlorophenol	N/A	N/A	N/A	N/A
2,4-Dichlorophenoxy acetic acid (2,4-D)	N/A	N/A	N/A	N/A
Diclofop-methyl	N/A	N/A	N/A	N/A
Dimethoate	N/A	N/A	N/A	N/A
Dinoseb	N/A	N/A	N/A	N/A
Diquat	N/A	N/A	N/A	N/A
Diuron	N/A	N/A	N/A	N/A
Glyphosate	N/A	N/A	N/A	N/A
Heptachlor + Heptachlor Epoxide	N/A	N/A	N/A	N/A
Lindane (Total)	N/A	N/A	N/A	N/A
Malathion	N/A	N/A	N/A	N/A
Methoxychlor	N/A	N/A	N/A	N/A
Metolachlor	N/A	N/A	N/A	N/A
Metribuzin	N/A	N/A	N/A	N/A
Monochlorobenzene	N/A	N/A	N/A	N/A
Paraquat	N/A	N/A	N/A	N/A
Parathion	N/A	N/A	N/A	N/A
Pentachlorophenol	N/A	N/A	N/A	N/A
Phorate	N/A	N/A	N/A	N/A
Picloram	N/A	N/A	N/A	N/A
Polychlorinated Biphenyls(PCB)	N/A	N/A	N/A	N/A
Prometryne	N/A	N/A	N/A	N/A
Simazine	N/A	N/A	N/A	N/A
THM – Jan, Apr, July, Oct – ug/L	59.6	52.8	66.5	123
THM Annual Average - ug/L	72.9	73.5	71.9	75.4
Temephos	N/A	N/A	N/A	N/A
Terbufos	N/A	N/A	N/A	N/A
Tetrachloroethylene	N/A	N/A	N/A	N/A
2,3,4,6-Tetrachlorophenol	N/A	N/A	N/A	N/A
Triallate	N/A	N/A	N/A	N/A
Trichloroethylene	N/A	N/A	N/A	N/A
2,4,6-Trichlorophenol	N/A	N/A	N/A	N/A
2,4,5-Trichlorophenoxy acetic acid (2,4,5-T)	N/A	N/A	N/A	N/A
Trifluralin	N/A	N/A	N/A	N/A
Vinyl Chloride	N/A	N/A	N/A	N/A

List any Inorganic or Organic parameter(s) that exceeded half the standard prescribed in Schedule 2 of Ontario Drinking Water Quality Standards.

Parameter	Result Value	Unit of Measure	Date of Sample
THMs	75.4	ug/L	Running Annual Avg